


# The potential benefits of natural gas storage to wind infrastructure development in Wyoming

Brian Jeffries  
May 19, 2009

# Wind supply and load demand are often mismatched



Source: Western Area Power Administration, *Wind Production Summary Overview*, October 2006.

## Supply of wind is variable during the day

- Xcel Energy system for Colorado has 775 MW of wind generation capacity
- Observed maximum one hour increase in output has been 96% of nameplate capacity
- Observed maximum one hour decrease in output has been 63% of nameplate capacity
- Resources on Xcel are reasonably dispersed

## Natural gas supply schedule for traditional service

- Four cut off times to schedule natural gas for delivery tomorrow
- Last chance to schedule a full load of gas for tomorrow late today
- Limited opportunity to make changes today for today
- Exception is “no notice service”

## Pipelines vary on policy for variable flow

- “quantities...shall not exceed in an hour  $1/24^{\text{th}}$  of Scheduled Quantity”
- “Transporter and Shipper will undertake to maintain receipts and deliveries...uniform hourly basis”
- “each Party shall use reasonable efforts...reasonably uniform hourly...rates of flow
- “Shipper shall use reasonable efforts...uniform hourly...rates of flow”

## Pipelines try to accommodate, but have the final say...

- “Transporter will have the right to take actions of whatever nature...to correct any imbalances...that impair...or threaten the integrity of its system”
- “Transporter may periodically have the right to take unilateral action...to preserve...operational integrity”
- “Nothing...shall limit Transporter’s right to take actions of whatever nature may be required...”

# Gas supply needed to replace wind drop

Wind Capacity	100 MW	200 MW	400 Mw
One Hour of lost generation	63 MW	126 MW	252 MW
Replace 1 hour with gas	650 MMBtu	1,300 MMBtu	2,600 MMBtu
Replace 8 hours with gas	5,200 MMBtu	10,500 MMBtu	21,000 MMBtu
Replace 16 hours with gas	10,400 MMBtu	21,000 MMBtu	42,000 MMBtu

Gas generation assumed at 10.45 MMBtu/MWH

## No notice gas supply service

- Historical artifact of almost every system
- Legacy storage used
- Usually a “bundled” service
- Sold out as a “bundled” service on every existing system
- New facilities have and can be built – storage is key

# Gas supply scenario with storage

- Typical storage facility can withdraw 2x injection
- Buy gas for each day equal to  $1/3^{\text{rd}}$  of demand
- If wind blows – inject to storage
- If wind dies – withdraw from storage to augment gas that was purchased
- How much storage to buy depends on field characteristics

# Simple example

- If no wind, assume daily gas demand 30,000 MMBtu for the power plant
- Buy 10,000 MMBtu every day
- If wind does blow hard – inject 10,000 MMBtu
- If wind doesn't blow at all – withdraw 20,000 MMBtu and have 30,000 MMBtu of total supply

# Other considerations

- Gas generation relative to wind farm location flexible
- Gas generation and storage should be on common pipeline
- Connection to large line better
- Gas generation at or upstream of storage and other loads is best
- Could lower unit cost of power lines

# WPA activities

- Provide forum for storage projects
- Support projects before FERC
- Share information with WIA
- Generate the discussion